

## Safety and Compliance Information

### For Information in Other Languages



**English:** To download a language version of this Safety and Compliance Information: 1. Find the **product article number** on the product cover. 2. **Scan the QR code** to access [www.anybus.com/support](http://www.anybus.com/support). 3. Enter the product article number to search for the product specific support web page.

**Deutsch:** Zum Herunterladen einer Sprachversion dieser Sicherheits- und Konformitätsinformationen: 1. Suchen Sie die **Artikelnummer des Produkts** auf der Produktabdeckung. 2. **Scannen Sie den QR-Code**, um auf [www.anybus.com/support](http://www.anybus.com/support) zuzugreifen. 3. Geben Sie die Artikelnummer des Produkts ein, um die produktspezifische Support-Webseite zu suchen.

**Español:** Para descargar una versión de esta información de seguridad y cumplimiento en un idioma concreto: 1. Busque el **número de artículo del producto** en la portada del producto. 2. **Escanee el código QR** para acceder a [www.anybus.com/support](http://www.anybus.com/support). 3. Introduzca el número de artículo del producto para buscar la página web de soporte específica del producto.

**Français:** Pour télécharger une version linguistique de ces informations sur la sécurité et la conformité : 1. Trouvez le **numéro d'article du produit** sur le couvercle du produit. 2. **Scannez le code QR** pour accéder à [www.anybus.com/support](http://www.anybus.com/support). 3. Saisissez le numéro d'article du produit pour rechercher la page Web d'assistance spécifique au produit.

**Italiano:** Per scaricare una versione di queste informazioni sulla sicurezza e sulla conformità nella tua lingua: 1. Trova il **numero di serie del prodotto** sulla confezione. 2. **Scansiona il codice QR** per accedere a [www.anybus.com/support](http://www.anybus.com/support). 3. Inserisci il numero di serie del prodotto per cercare la pagina web di supporto dedicata al prodotto.

**日本語:** この「安全およびコンプライアンス情報」の各言語バージョンをダウンロードするには : 1.製品のカバーにある**製品番号**を確認します。2.**QRコードをスキャン**して [www.anybus.com/support](http://www.anybus.com/support) にアクセスします。3.製品番号を入力して、その製品に関するサポートウェブページを検索します。

**Svenska:** Så laddar du ner en språkversion av denna information om säkerhet och regelbaserad: 1. Leta rätt på **produktens artikelnummer** på produktens hölje. 2. **Skanna QR-koden** för att öppna [www.anybus.com/support](http://www.anybus.com/support). 3. Ange produktens artikelnummer för att söka efter den produktspecifika supportwebbsidan.

### Warning Levels



#### WARNING

Instruction that must be followed to avoid a risk of death or serious injury.



#### CAUTION

Instruction that must be followed to avoid a risk of personal injury.

### General Safety



#### CAUTION

This equipment emits RF energy in the ISM (Industrial, Scientific, Medical) band. Make sure that all medical devices used in proximity to this equipment meet appropriate susceptibility specifications for this type of RF energy.



#### CAUTION

This equipment contains parts that can be damaged by electrostatic discharge (ESD). Use ESD prevention measures to avoid damage.



#### CAUTION

If this equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.



#### CAUTION

Connecting power with reverse polarity or using the wrong type of power supply may damage the equipment. Make sure that the power supply is connected correctly and of the recommended type.



#### CAUTION

This equipment is not intended for use in an environment where children are present. Keep out of reach of children.


### Intended Use

The intended use of this equipment is as a communication interface and gateway. The equipment receives and transmits data on various physical and wireless levels and connection types.

### Model Identification


Hardware description	Model identification
Functionality: Ethernet	AWB6BA
Interface configuration: RJ45 and 3-pin power socket	

### Installation



- Mount the Bolt II (1) on a machine or cabinet.
- Mounting hole diameter: M50 (50,5 mm)
- Ensure to use the included sealing (2) ring and lock nut (3).
- Bolt II lock nut (3) tightening torque: 5 Nm  $\pm$  10 %
- The top mounting surface, in contact with the sealing, must be:
  - flat with a finish equivalent to Ra 3.2 or finer.
  - cleaned and free from oils and greases.
- Use 0.25 - 1.5 mm<sup>2</sup> (24-16 AWG) cable for supply wiring.
- If the Ethernet cables are to be exposed in an outdoor environment, transient protection must be provided.
- Use minimum 90 °C copper (Cu) wire only.
- Use in Overvoltage Category II Pollution Degree 2 Environment conforming to EN 60664-1.
- This equipment is designed to comply as Class III equipment according to 61010-2-201.

### Connectors



Power Connector 3-Pin			
Pin			
1	+	Recommended: 12–24 VDC Reverse voltage protection Min: 10 VDC Max: 33 VDC	
2	-		
3		Functional Earth (FE)	

Ethernet Connector RJ45 PoE					
Pin	Data	PoE	Pin	Data	PoE
1	TD+	A+	5	N/A	B+
2	TD-	A+	6	RD-	A-
3	RD+	A-	7	N/A	B-
4	N/A	B+	8	N/A	B-
					Shield

### For Use in North America and/or Canada

The unit shall be supplied by an isolated power source which fulfils the requirements of Limited-Energy Circuit in accordance with UL/CSA 61010-1/UL/CSA 61010-2-201 or Limited Power Source (LPS) in accordance with UL/CSA 60950-1 or a Class 2 supply source which complies with the National Electrical Code (NEC), NFPA 70, Clause 725.121 and Canadian Electrical Code (CEC), Part I, C22.1.

### For Use in Europe

The unit shall be supplied by LPS Power Source in accordance with the IEC 62368-1.

Technical Specifications

Model identification	AWB6BA
Communication connector	RJ45
Power connector	3-pole push-in spring connection
Power supply	Recommended: 12–24 VDC Reverse voltage protection Min: 10 VDC Max: 33 VDC Max power: 2.5 W
Power over Ethernet (PoE)	IEEE 802.3af/802.3at Type 1 Class 3 Typical: 1.45 W Max: 2.7 W Voltage range: 37-57 V
Power consumption	Typical: 60 mA @ 24 V Max: 110 mA @ 24 V
Antenna	MIMO 802.11 a/b/g/n and 802.11ac
Wireless LAN	2.4 GHz, channel 1-11 + 12-13 depending on regulatory domain scan 5 GHz Access Point: 36-48 (U-NII-1) 5 GHz Client: 100-116 + 132-140 and 120-128 (U-NII-1, U-NII-2, U-NII-2e) depending on regulatory domain scan RF output power: 18 dBm
Storage temperature	-40 to +85 °C
Operating temperature	-25 to +65 °C
Humidity	EN 600068-2-78: Damp heat, +40°C, 93% humidity for 4 days.
Vibration	See datasheet
Housing material	Plastic (see data sheet for details) Aluminum (see data sheet for details)
Protection class	Top (outside of host): IP66 / UL Type 4X Base (inside of host): IP30
Product weight	284 g
Dimensions	113 x 59 x 113 mm (W x H x D)
Mounting	M50 screw and nut. 50.5 mm hole needed.

Additional technical data and information related to the installation and use of this product can be found at [www.anybus.com/support](http://www.anybus.com/support).

CE Compliance



This product is in compliance with the EMC Directive 2014/30/EU and the RoHS Directive 2011/65/EU with amendment 2015/863 through conformance with applicable standards. The full text of the Declaration of Conformity is available at [www.anybus.com/support](http://www.anybus.com/support).

UKCA Compliance



This product is in compliance with the Electromagnetic Compatibility Regulations 2016. The full text of the Declaration of Conformity is available at [www.anybus.com/support](http://www.anybus.com/support).

Disposal and Recycling



You must dispose of this equipment properly according to local laws and regulations. Because this equipment contains electronic components, it must be disposed of separately from household waste. When this equipment reaches its end of life, contact local authorities to learn about disposal and recycling options, or return the equipment to HMS. For more information, see [www.hms-networks.com](http://www.hms-networks.com).

UL Ordinary Locations (OrdLoc)

This equipment is certified for use in ordinary locations in compliance with the following standards:

- UL 61010-1 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS
- UL 61010-2-201 STANDARD FOR SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 2-201: PARTICULAR REQUIREMENTS FOR CONTROL EQUIPMENT
- CSA C22.2 NO. 61010-1-12 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE. PT. 1, GENERAL REQUIREMENTS
- CSA C22.2 NO. 61010-2-201:14 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 2-201: PARTICULAR REQUIREMENTS FOR CONTROL EQUIPMENT

The certification number for the OrdLoc certified equipment is: **E214107**

According to the standards listed above, the equipment is certified with the following marking:



IND. CONT. EQ.  
**E214107**